

Anchor				Connector				High Sign				Pole (continued)				Trans_Dist Pole			
Broken/Damaged	Repair		E	Burnt	Replace		E	Missing	Install		F-R	No Safe Access	Inspect		B	Bonding Broken	Repair		E
	Replace		E		Corroded	Repair			E	Insulator					Woodpecker Damage		Assess		E
Corroded	Repair		E	Temp Differential		Replace		E	Broken/Damaged		Replace		E	Pole Step					Broken/Damaged
	Replace		E		Incorrect	Replace		E		Flasher	Replace		E		Clearance Impaired	Remove		F-R	
Missing	Install		F-R	Crossarm					Squatter (Primary)		Repair		E	Recloser / Sectionalizer					Flasher
Soil/Eroded/Graded	Adjust		F-R		Broken/Damaged	Repair		E		Squatter (Secondary)	Replace		E		Broken/Damaged	Replace		E	
	Replace		F-R	Burnt		Replace		E	LAPP Broken		Replace		E	Leaks/Seeps/Weeps		Clean		B	Leaks/Seeps/Weeps
Animal Mitigation					Decayed/Rotten	Replace		E		Jumper					Excessive Operation	Overhaul		E	
Mitigation Missing	Install		E	Cutout		Repair		E	Burnt		Replace		E	Flasher		Repair		E	Tree / Vine
Broken	Replace		E		Broken/Damaged	Replace		E		Clearance	Adjust		E		Flasher	Replace		E	
Booster / Regulator				Flasher		Replace		E	Lightning Arrestor					Riser / Pothead					Decayed/Rotten
Broken/Damaged	Repair		E		Clearance	Adjust		F-R		Broken/Damaged	Replace		F-R		Broken/Damaged	Repair		E	
Burnt	Repair		E	Flasher		Replace		E	Missing		Install		F-R	Flasher		Replace		F-R	Trim
Excessive Operation	Overhaul		E		Fault Indicator					Molding					RTVI				
Leaks/Seeps/Weeps	Clean		B	Broken/Damaged	Replace		E	Broken/Damaged	Repair		F-R	Interference	Repair		E	*Migratory Bird Notifications Only (2AB, KAC)			
	Repair		B		Ground					Loose	Adjust			F-R	Replace				
	Replace		B	Exposed		Repair		F-R	Missing		Install		F-R	SCADA / PDAC					
Capacitor					Missing	Install		E		OH Facility					Broken/Damaged	Repair		F-R	OH Facility / Bird Protection Required / Install (OFAC/BRDQ/INST)
Broken/Damaged	Repair		E	Guy					Graffiti	Paint		E	Leaks/Seeps/Weeps	Replace			F-R	Hardware/Framing / Bird Protection Required / Install (HARD/BDRQ/INST)	
	Replace		E		Broken/Damaged	Repair		E		Limited Access/ Obstruct	Inspect			E	Leak/Seeps/Weeps	Repair			B
Burnt	Repair		E	Clearance		Adjust		F-R	Idle Facilities		De-Energize		E	Test			B		
	Replace		E		Corroded	Replace		E		Transfer									
Leaks/Seeps/Weeps	Clean		B	Loose		Adjust		F-R	Pole				Steel Lattice Pole				To Replace Existing, Deteriorated Bird Protection Only		
	Repair		B		Missing	Install		F	Broken/Damaged	Repair		E	Guard Missing	Install		E			
	Replace		B	Overgrown		Trim		F-R		Burnt	Replace			E	Broken/Damaged	Replace		E	*EMERGENCY ONLY TEMPORARY REPAIR: <input type="checkbox"/>
Climbing Space					Strain / Abrasion	Adjust		F-R	Clearance		Repair		E	Missing		Install		E	
Obstructed	Adjust		F-R	Guy Marker		Remove		F-R		Decayed/Rotten	Replace		E		Loose	Replace		E	
Conductor					Missing	Install		F-R	Clearance		Replace		E	Broken/Damaged		Replace		E	Version 1.12 Effective 02/14/2019
Broken/Damaged	Repair		E	Hardware / Framing				Pole Top Repair					Switch						
	Replace		E	Broken/Damaged	Repair		E		Stub					Tie Wire					
Burnt	Repair		E		Loose	Adjust		E		Idle Facilities	Remove		E		Broken/Damaged	Repair		E	
	Replace		E	Missing		Install		E	Leaning		Adjust		E	Leak/Seeps/Weeps		Replace		E	
Clearance	Adjust		E		Overloaded	Replace		E		Test					Equip Failed	Tree Contact			
	Install CL Pole		E	Decayed/Rotten		Repair		E	Fire					Lightning		Unknown			
	RayChem		E		Priority Due Date Reference: A = Emergency B = Within 3 months (Urgent) E = Within 12 Months F = Date of Next Inspection Cycle	Missing	Install			E	Overloaded	Replace			E	Pole Rotten			
Idle Facilities	Remove		E					EMERGENCY ONLY Check Cause (Required)											
Floater	Repair		E																
Improper Connection	Adjust		E																
Overloaded	Test		E																
Sag / Clearance	Adjust		E																
	Replace		E																
Compelling=Any condition that needs to be addressed in the next 5 years																			
New = Identify All FDA's identified in the field																			
Priority=Default-B E F FR																			
adjust depending on exposure																			